MEMORANDUM OF UNDERSTANDING ON PORT STATE CONTROL IN THE ASIA-PACIFIC REGION



CONCENTRATED INSPECTION CAMPAIGN ON FIRE SAFETY 01/09/2023 to 30/11/2023

CIC on FIRE SAFETY						
Inspection Authority						
Ship Name	IMO Number					
Date of Inspection	Inspection Port					

QUESTIONS 1 TO 10 ANSWERED WITH A "NO" MUST BE ACCOMPANIED BY A RELEVANT DEFICIENCY ON THE REPORT OF INSPECTION.

No.	Item	Yes	No	N/A	Detention
1*	Are the emergency escape routes maintained in a safe condition? (07120/04103)				
2*	Are the fire doors maintained in good working condition? (07105)				
3*	Has the fixed fire detection and fire alarm systems, been periodically tested in accordance with the requirements of the Administration? (07106)				
4*	Are ventilation closing appliances capable of being closed? (07116)				
5*	Are the means of control for power ventilation of machinery spaces operable from two grouped positions? (07116)				
6*	Can each fire pump deliver at least the two required jets of water? (07113)				
7*	Are the means of control provided in a position outside the machinery space for stopping ventilation and oil transfer equipment operational? (07114)				
8*	Is the room for the fixed gas fire extinguishing medium used only for this purpose? (07109)				
9*	Are the valves used in the fire main line operational? (07110)				
10*	Where a fire drill was witnessed, was it found to be satisfactory? (04109/07125)				

Note: If "No" is ticked for questions marked with an asterisk "*", the ship may be considered for detention.